

Summary Report of Hazardous Waste and Sewage Spill Incidents per Water Code Section 13271

I. Petroleum Products

Date Reported*	Date Discovered	Location	Discharger	Problem	Action
11/30/2000		7491 LA PALMA AVENUE, BUENA PARK	SHELL STATION (FORMER)	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL AND GROUNDWATER	INVESTIGATION IN PROGRESS
1/9/2002		11090 MAGNOLIA, RIVERSIDE	SHELL SERVICE STATION	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL AND GROUNDWATER	INVESTIGATION IN PROGRES
1/15/2002		2037 CHAPMAN AVENUE, ORANGE	ARCO #9537	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL AND GROUNDWATER	INVESTIGATION IN PROGRES
8/7/1998		USMCAS TUSTIN BLDG 539, TUSTIN	USMCAS TUSTIN UST 135	UNDERGROUND STORAGE TANK LEAK: FUEL OIL CONTAMINATED SOIL AND GROUNDWATER	INVESTIGATION IN PROGRESS
2/1/2002		3731 EAST LA PALMA AVENUE, ANAHEIM	TOSCO/76 #5215	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	INVESTIGATION IN PROGRES
		EASTERN FLIGHT LINE, LOS ALAMITOS	JOINT FORCES TRAINING BASE, LOS ALAMITOS	UNDERGROUND STORAGE TANK LEAK:DIESEL CONTAMINATED SOIL	INVESTIGATION IN PROGRES
1/24/2002	11/6/1997	6001 ORANGE AVENUE, CYPRESS	SHELL OIL COMPANY	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL AND GROUNDWATER	INVESTIGATION IN PROGRESS
9/22/2000		1200 STATE COLLEGE BLVD., N, ANAHEIM	EXXONMOBIL #18-F5Q	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	INVESTIGATION IN PROGRES
11/24/1987		BLDG 43 AIRCRAFT PARKING, LOS ALAMITOS	JOINT FORCES TRAINING BASE, LOS ALAMITOS	UNDERGROUND STORAGE TANK LEAK: WASTE OIL CONTAMINATED SOIL	INVESTIGATION IN PROGRES
11/24/1987		BLDG 37 AIRCRAFT PARKING RAMP, LOS ALAMITOS	JOINT FORCES TRAINING BASE, LOS ALAMITOS	UNDERGROUND STORAGE TANK LEAK: FUEL OIL CONTAMINATED SOIL	INVESTIGATION IN PROGRESS
3/5/2002		2302 S. BRISTOL STREET, SANTA ANA	SHELL SERVICE STATION	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL AND GROUNDWATER	INVESTIGATION IN PROGRES
1/17/2002		1265 VAN BUREN, ANAHEIM	PACIFIC BELL	UNDERGROUND STORAGE TANK LEAK: DIESEL CONTAMINATED SOIL	NO FURTHER ACTION

*Report date is the date on the Unauthorized Release Report which is filled out by the local agency or the discharger.

Summary Report of Hazardous Waste and Sewage Spill Incidents per Water Code Section 13271

I. Petroleum Products

Date Reported*	Date Discovered	Location	Discharger	Problem	Action
1/18/2002		3539 HOWARD WAY, COSTA MESA	RYDER TRUCK	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	INVESTIGATION IN PROGRESS
		1625 LEWIS ST., S., ANAHEIM	COORS DISRIBUTING COMPANY	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	INVESTIGATION IN PROGRES
3/5/1991		SITE 43 35TH STREET, RIVERSIDE	MARCH AIR FORCE BASE (FORMER)	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL AND GROUNDWATER	INVESTIGATION IN PROGRES
		BDLG 27 BUNKER HILL AVE., LOS ALAMITOS	JOINT FORCES TRAINING BASE, LOS ALAMITOS	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	INVESTIGATION IN PROGRESS
2/15/2002		300 EAST, S., ANAHEIM	ANAHEIM SERVICE STATION	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	INVESTIGATION IN PROGRES
		BLDG 2 Doolittle Ave., LOS ALAMITOS	JOINT FORCES TRAINING BASE, LOS ALAMITOS	UNDERGROUND STORAGE TANK LEAK: DIESEL CONTAMINATED SOIL	INVESTIGATION IN PROGRES
1/15/2002	6/15/2001	5012 LINCOLN AVE, CYPRESS	ARCO #1738	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL AND GROUNDWATER	INVESTIGATION IN PROGRESS
3/31/1988	3/24/1988	3539 HOWARD WAY, COSTA MESA	RYDER TRUCK RENTAL	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL AND GROUNDWATER	INVESTIGATION IN PROGRES
11/24/1987		4250 CONSTITUTION AVE, LOS ALAMITOS	JOINT FORCES TRAINING BASE, LOS ALAMITOS	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL AND GROUNDWATER	INVESTIGATION IN PROGRES

*Report date is the date on the Unauthorized Release Report which is filled out by the local agency or the discharger.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notif. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
2/1/02	2/1/02	24061	Irvine Ranch Water District	2953 Edinger, Irvine, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to unspecified blockage. Approximately 20% of the spill was contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into a nearby storm drain. The blockage was cleared; the affected area was cleaned up, and disinfected by Irvine Ranch Water District staff.
2/7/02	2/7/02	24059	City of Orange	275 - 279 S Main St, Orange, Orange County	SSO	793	An estimated 793 gallons of sewage overflowed from a manhole due to a grease blockage. An unspecified amount of the spill was contained, recovered, and returned to the operational sewer system, while the remaining of the spill discharged into a local storm drain. The blockage was cleared; the affected area was cleaned up and disinfected by City of Orange staff.
2/9/02	2/9/02	24063	City of Stanton	7721 Cerritos, Stanton, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to unknown blockage. Approximately 300 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into a local storm drain. The blockage was cleared; the affected area was cleaned up, and disinfected by City of Stanton staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notif. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
2/13/02	2/13/02	24055	Irvine Ranch Water District	Sharmila & Masurca, Lake Forest, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a sewer line break. All 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The line break was repaired; the affected area was cleaned up, and disinfected by Irvine Ranch Water District staff.
2/16/02	2/16/02	24056	City of Huntington Beach	9511 Olympic, Huntington Beach, Orange County	SSO	1,600	An estimated 1,600 gallons of sewage overflowed from a manhole due to a grease blockage. All 1,600 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared; the affected area was cleaned up, and disinfected by City of Huntington Beach staff.
2/16/02	2/16/02	24057	City of Huntington Beach	129 N Bitterbush, Orange, Orange County	SSO	600	An estimated 600 gallons of sewage overflowed from a manhole due to unknown blockage. Approximately 100 gallons of the spill were contained, recovered, and returned to the operational sewer system. 500 gallons of the spill were not recovered and discharged into a local storm drain. The blockage was cleared; the affected area was cleaned up, and disinfected by City of Huntington Beach staff.
2/20/02	2/20/02	24058	Private Property Owner	5096 Tortuga, Suite #103, Huntington Beach, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a private lateral due to unspecified blockage. All 500 gallons of the spill discharged into a local storm drain. The blockage was cleared; the affected area was cleaned up, and disinfected by the private property owner.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notif. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
2/22/02	2/22/02	24102	Private Property Owner, Jolly Roger Inn	640 W Katella, City of Anaheim, Orange County	SSO	2,000	An estimated 2,000 gallons of sewage overflowed from a private lateral due to grease blockage. Approximately 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the remaining 1,000 gallons of the spill discharged into a local storm drain. The blockage was cleared; the affected area was cleaned up, and disinfected by the private property owner.
2/22/02	2/22/02	24103	El Toro Water District	23542 Moulton Pkwy, Laguna Hills, Orange County	SSO	178,000	An estimated 178,000 gallons of sewage overflowed from a manhole due to a pump failure at a lift station. Approximately 3,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. 177,700 gallons of the spill discharged into a local storm drain which leads to the Veeh Lakes stormwater retention ponds. The equipment was repaired and the affected area was cleaned up by El Toro Water District staff.
2/26/02	2/26/02	24054	Big Bear City	1200 Minton, Big Bear City, San Bernardino County	SSO	14,400	An estimated 14,400 gallons of sewage overflowed from a sewer line break. An unspecified amount of the spill was contained and returned to the operational sewer system, while the rest of the spill discharged into a nearby storm drain. The line break was repaired and the affected area was cleaned up by City of Big Bear staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notif. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/6/02	3/6/02	24020	Private Property Owner, Leisure World Golf Course	Moulton & Santa Maria, City of Laguna Woods, Orange County	TRW	600	An estimated 600 gallons of tertiary recycled water (TRW) was released from an irrigation line break. All 600 gallons of the spill discharged into a local storm drain. The break was repaired and the affected area was cleaned up by El Toro Water District staff.
3/8/02	3/8/02	23900	Sunset Beach Sanitary District	Between 8th & 9th Street, Sunset Beach, Orange County	SSO	100	An estimated 100 gallons of sewage overflowed from a manhole due to concrete blockage. Approximately 40 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into Huntington Harbor. The OCHCA closed the harbor water area at Park Avenue Beach in Huntington Harbor. The blockage was cleared and the affected area cleaned up by Sunset Beach Sanitary District staff.
3/9/02	3/9/02	23913	Yorba Linda Water District	La Palma & Old Village Rd, Yorba Linda, Orange County	SSO	1,500	An estimated 1,500 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 200 gallons of the spill were contained, recovered, and returned to the operational sewer system. 1,300 gallons of the spill discharged into a local storm drain. The blockage was cleared; the affected area was cleaned up, and disinfected by Yorba Linda Water District.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notif. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/9/02	3/9/02	23950	City of Orange	660 S Glassel, Orange, Orange County	SSO	1,064	An estimated 1,064 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 300 gallons of the spill were contained, recovered, and returned to the operational sewer system. 764 gallons of the spill discharged into a local storm drain. The blockage was cleared; the affected area was cleaned up, and disinfected by the City of Orange staff.
3/12/02	3/11/02	23914	Western Municipal Water District	Next to Flight Line NE, March Air Force Base, Riverside County	SSO	1,500	An estimated 1,500 gallons of sewage was released from a 2" PVC lateral due to line break. All 1,500 gallons of the spill were contained, recovered, and returned to the operational sewer system. The line break was repaired; the affected area was cleaned up, and disinfected by Western Municipal Water District staff.
3/12/02	3/12/02	23957	Private Property Owner, Big Canyon Golf Course	21911 Big Canyon Dr, City of Newport Beach, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to root blockage. All 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared; the affected area was cleaned up, and disinfected by a private property owner with assistance of the City of Newport Beach staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notif. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/13/02	3/12/02	23955	Private Property Owner	Laurel Canyon & Arturo Way, Corona, Riverside County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to unknown blockage. All 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared; the affected area was cleaned up, and disinfected by the private property owner.
3/14/02	3/14/02	23907	Irvine Ranch Water District	Behine #34 - Timber Run, Irvine, Orange County	TRW	7,500	An estimated 7,500 gallons of tertiary recycled water (TRW) was released from an irrigation line break. All 7,500 gallons of the spill discharged into a local storm drain. The break was repaired and the affected area was cleaned up by Irvine Ranch Water District staff.
3/14/02	3/14/02	23909	Irvine Ranch Water District	Greenbelt - Sanberg & Mandrake, Irvine, Orange County	TRW	9,000	An estimated 9,000 gallons of tertiary recycled water (TRW) was released from a line break. All 9,000 gallons of the spill discharged into a local storm drain. The broken line was repaired and the affected area was cleaned up by Irvine Ranch Water District staff.
3/14/02	3/14/02	23908	Irvine Ranch Water District	Greenbelt - 88 W. Yale Loop Dr, Irvine, Orange County	TRW	6,000	An estimated 6,000 gallons of tertiary recycled water (TRW) was released from a broken sprinkler head. All 6,000 gallons of the spill discharged into a local storm drain. The broken line was repaired and the affected area was cleaned up by Irvine Ranch Water District staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notif. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/14/02	3/14/02	23943	City of Riverside	5090 Rockledge, Riverside, Riverside County	SSO	3,000	An estimated 3,000 gallons of sewage overflowed from a manhole due to unknown blockage. All 3,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared; the affected area was cleaned up, and disinfected by City of Riverside staff.
3/18/02	3/18/02	23902	City of Newport Beach	187 Shorecliff, Newport Beach, Orange County	SSO	200	An estimated 200 gallons of sewage overflowed from a manhole due to root blockage. Approximately 50 gallons of the spill were contained, recovered, and returned to the operational sewer system. 150 gallons of the spill discharged into the Pacific Ocean. The OCHCA closed 100 yards of ocean water area at Cameo Shores in the City of Newport Beach. The blockage was cleared and the affected area was cleaned up by Newport Beach City staff.
3/18/02	3/18/02	23918	Costa Mesa Sanitary District	Irvine Ave & Santiago, Newport Beach, Orange County	SSO	1,500	An estimated 1,500 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 200 gallons of the spill were contained, recovered, and returned to the operational sewer system. 1,300 gallons of the spill discharged into a local storm drain. The blockage was cleared; the affected area was cleaned up, and disinfected by Costa Mesa Sanitary District staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notif. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/18/02	3/18/02	23915	Rancho Cucamonga Water District	Hellman at 8th, Rancho Cucamonga, San Bernardino County	SSO	3,000	An estimated 3,000 gallons of sewage overflowed from a manhole due to unknown blockage. All 3,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared; the affected area was cleaned up, and disinfected by Rancho Cucamonga Water District staff.
3/18/02	3/18/02	23904	Private Property Owner, Ruby's Diner @ Balboa Pier	Balboa Pier, Newport Beach, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a private lateral due to unknown blockage. All 500 gallons of the spill discharged into the Pacific Ocean. The OCHCA closed the ocean water area 1,000 feet downcoast of the Balboa Pier in the City of Newport Beach. The blockage was cleared and the affected area was cleaned up by the private property owner.
3/19/02	3/19/02	23905	Private Property Owner, West Bay Café	16600 P.C.H., Huntington Beach, Orange County	SSO	100	An estimated 100 gallons of sewage overflowed from a private lateral due to grease blockage. Approximately 20 gallons of the sewage were contained, recovered, and returned to the operational sewer system. 80 gallons of the spill discharged into a local storm drain and flowed to Huntington Harbor. OCHCA closed the Huntington Harbor water area of Admiralty Drive and 11th Street. The blockage was cleared and the affected area was cleaned up by the private property owner.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notif. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/19/02	3/19/02	24013	City of La Habra Public Utilities Department	Verna Ave & Orange St, La Habra, Orange County	SSO	1,250	An estimated 1,250 gallons of sewage overflowed from a manhole due to unknown blockage. All 1,250 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared; the affected area was cleaned up, and disinfected by City of La Habra staff.
3/21/02	3/21/02	23912	City of Garden Grove	5752 Anthony St, Garden Grove, Orange County	SSO	3,120	An estimated 3,120 gallons of sewage overflowed from a manhole due to grease blockage. An unspecified amount of the spill was contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Garden Grove staff.
3/21/02	3/21/02	23938	Private Property Owner	Roosevelt & Monroe, Irvine, Orange County	TRW	3,000	An estimated 3,000 gallons of tertiary recycled water (TRW) was released from an irrigation line break. All 3,000 gallons discharged into a local storm drain. The broken line was repaired and the affected area was cleaned up by the private property owner.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notif. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/21/02	3/21/02	23939	Private Property Owner	East Yale & Woodspring, Irvine, Orange County	TRW	750	An estimated 750 gallons of tertiary recycled water (TRW) was released from an irrigation line break. All 750 gallons of the spill discharged into a local storm drain. The broken line was repaired and the affected area was cleaned up by the private property owner.
3/22/02	3/22/02	23960	City of La Habra	100 Block of N Orange, La Habra, Orange	SSO	750	An estimated 750 gallons of sewage overflowed from a manhole due to unknown blockage. All 750 gallons of the spill discharged into a creek where 8,000 gallons of the spill and creek water were contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up by City of La Habra staff.